



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing



ANALYTICAL RESULTS

STANDARD DELIVERABLES FORMAT

APL WORK ORDER NUMBER: 2040963

Pompton Lakes MUA

Project: None Given

Brian Wood
Laboratory Director

All Results meet the requirements of the National Environmental Laboratory Accreditation Conference and/or
State specific certifications as applicable.

Report Date: Apr 27, 2022



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-01 (Drinking Water)

HS-DW-JU-02 (High School)

Collected
04/19/2022 09:13

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 12:49	04/26/22 12:49	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-02 (Drinking Water)

HS-DW-SO-01 (High School)

Collected
04/19/2022 08:58

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 12:51	04/26/22 12:51	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-03 (Drinking Water)

HS-DW-SO-02 (High School)

Collected
04/19/2022 08:57

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 12:53	04/26/22 12:53	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-04 (Drinking Water)

HS-DW-SO-03 (High School)

Collected
04/19/2022 09:23

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 12:56	04/26/22 12:56	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-05 (Drinking Water)

HS-DW-SE-01 (High School)

Collected
04/19/2022 08:47

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 13:00	04/26/22 13:00	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-06 (Drinking Water)

HS-DW-SE-02 (High School)

Collected
04/19/2022 08:54

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 13:02	04/26/22 13:02	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-07 (Drinking Water)

HS-DW-SE-03 (High School)

Collected
04/19/2022 09:18

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 13:04	04/26/22 13:04	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-08 (Drinking Water)

HS-DW-SE-04 (High School)

Collected
04/19/2022 09:10

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 13:07	04/26/22 13:07	0.00235			0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-09 (Drinking Water)

HS-DW-RM115 (High School)

Collected
04/19/2022 09:02

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 13:09	04/26/22 13:09	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-10 (Drinking Water)

HS-Cafe-01 (High School)

Collected
04/19/2022 08:32

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 13:36	04/26/22 13:36	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-11 (Drinking Water)

HS-DW-RM-104 (High School)

Collected
04/19/2022 08:48

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 13:39	04/26/22 13:39	0.00232			0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-12 (Drinking Water)

HS-DW-RM-105 (High School)

Collected
04/19/2022 08:51

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 13:41	04/26/22 13:41	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-13 (Drinking Water)

HS-DW-OFF-01 (High School)

Collected
04/19/2022 08:52

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 13:44	04/26/22 13:44	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-14 (Drinking Water)

HS-DW-RM-113 (High School)

Collected
04/19/2022 09:01

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 13:46	04/26/22 13:46	0.0401			0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-15 (Drinking Water)

HS-DW-RM-117 (High School)

Collected
04/19/2022 09:04

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 13:48	04/26/22 13:48	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-16 (Drinking Water)

HS-HEC-01 (High School)

Collected
04/19/2022 08:41

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 13:51	04/26/22 13:51	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-17 (Drinking Water)

HS-HEC-02 (High School)

Collected
04/19/2022 08:42

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 13:58	04/26/22 13:58	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-18 (Drinking Water)

HS-HEC-03 (High School)

Collected
04/19/2022 00:00

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 14:00	04/26/22 14:00	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-19 (Drinking Water)

HS-HEC-04 (High School)

Collected
04/19/2022 00:00

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 14:03	04/26/22 14:03	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-20 (Drinking Water)

HS-HEC-05 (High School)

Collected
04/19/2022 00:00

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 14:05	04/26/22 14:05	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-21 (Drinking Water)

HS-DW-TR (High School)

Collected
04/19/2022 00:00

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 14:07	04/26/22 14:07	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-22 (Drinking Water)

HS-ICE-01 (High School)

Collected
04/19/2022 00:00

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 14:10	04/26/22 14:10	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-23 (Drinking Water)

HS-DW-LRB (High School)

Collected
04/19/2022 00:00

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 14:12	04/26/22 14:12	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-24 (Drinking Water)

HS-DW-LRG (High School)

Collected
04/19/2022 00:00

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 14:14	04/26/22 14:14	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-25 (Drinking Water)

LIM-03 (Lincoln)

Collected
04/19/2022 10:32

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 14:17	04/26/22 14:17	0.00293			0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-26 (Drinking Water)

LIM-06 (Lincoln)

Collected
04/19/2022 10:31

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 14:19	04/26/22 14:19	0.00711			0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-27 (Drinking Water)

LIM-07 (Lincoln)

Collected
04/19/2022 10:33

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 14:26	04/26/22 14:26	0.00268			0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-28 (Drinking Water)

LIM-08 (Lincoln)

Collected
04/19/2022 10:38

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 14:29	04/26/22 14:29	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-29 (Drinking Water)

LIM-09 (Lincoln)

Collected
04/19/2022 10:35

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 14:31	04/26/22 14:31	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-30 (Drinking Water)

LIM-10 (Lincoln)

Collected
04/19/2022 10:36

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 14:33	04/26/22 14:33	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-31 (Drinking Water)

LIM-11 (Lincoln)

Collected
04/19/2022 10:37

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 14:36	04/26/22 14:36	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-32 (Drinking Water)

LIM-12 (Lincoln)

Collected
04/19/2022 10:38

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 14:38	04/26/22 14:38	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-33 (Drinking Water)

LIM-13 (Lincoln)

Collected
04/19/2022 10:39

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 14:41	04/26/22 14:41	0.00221			0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-34 (Drinking Water)

LIM-14 (Lincoln)

Collected
04/19/2022 10:40

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 14:43	04/26/22 14:43	0.00395			0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-35 (Drinking Water)

LIM-15 (Lincoln)

Collected
04/19/2022 10:41

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 14:45	04/26/22 14:45	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-36 (Drinking Water)

LIM-16 (Lincoln)

Collected
04/19/2022 10:42

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 14:48	04/26/22 14:48	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-37 (Drinking Water)

LIM-17 (Lincoln)

Collected
04/19/2022 10:43

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 14:55	04/26/22 14:55	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-38 (Drinking Water)

LIM-20 (Lincoln)

Collected
04/19/2022 10:43

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 14:57	04/26/22 14:57	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-39 (Drinking Water)

LIM-22 (Lincoln)

Collected
04/19/2022 10:47

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 15:00	04/26/22 15:00	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-40 (Drinking Water)

LIM-23 (Lincoln)

Collected
04/19/2022 10:44

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 15:02	04/26/22 15:02	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-41 (Drinking Water)

LIM-38 (Lincoln)

Collected
04/19/2022 10:45

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 15:04	04/26/22 15:04	0.00547			0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)

Analytical Results Summary

2040963-42 (Drinking Water)

LIM-39 (Lincoln)

Collected 04/19/2022 10:48	Received 04/20/2022 15:30	Contact Billy Doty
-------------------------------	------------------------------	-----------------------

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 15:07	04/26/22 15:07	0.0160			0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-43 (Drinking Water)

LIM-40 (Lincoln)

Collected
04/19/2022 10:50

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 15:09	04/26/22 15:09	0.00628			0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-44 (Drinking Water)

LIM-41 (Lincoln)

Collected
04/19/2022 10:50

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 15:11	04/26/22 15:11	0.00645			0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-45 (Drinking Water)

LIM-42 (Lincoln)

Collected
04/19/2022 10:52

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 15:14	04/26/22 15:14	0.00527			0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-46 (Drinking Water)

LIM-43 (Lincoln)

Collected
04/19/2022 10:51

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 15:16	04/26/22 15:16	0.00494			0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-47 (Drinking Water)

LIM-44 (Lincoln)

Collected
04/19/2022 10:53

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 15:23	04/26/22 15:23	0.00508			0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-48 (Drinking Water)

LIM-45 (Lincoln)

Collected
04/19/2022 10:55

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 15:26	04/26/22 15:26	0.00827			0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-49 (Drinking Water)

LI-M-25 (Lincoln)

Collected
04/19/2022 10:46

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 15:28	04/26/22 15:28	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-50 (Drinking Water)

LI-M-Cafe (Lincoln)

Collected
04/19/2022 10:59

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 15:30	04/26/22 15:30	0.00606			0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-51 (Drinking Water)

LE-DW-0101 (Lenox)

Collected
04/19/2022 09:35

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 15:33	04/26/22 15:33	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-52 (Drinking Water)

LE-DW-0102 (Lenox)

Collected
04/19/2022 09:36

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 15:35	04/26/22 15:35	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-53 (Drinking Water)

LE-DW-0103 (Lenox)

Collected
04/19/2022 09:36

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 15:37	04/26/22 15:37	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-54 (Drinking Water)

LE-DW-0104 (Lenox)

Collected
04/19/2022 09:39

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 15:40	04/26/22 15:40	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-55 (Drinking Water)

LE-DW-0105 (Lenox)

Collected
04/19/2022 09:43

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 15:42	04/26/22 15:42	0.00235			0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-56 (Drinking Water)

LE-DW-0106 (Lenox)

Collected
04/19/2022 09:41

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 15:45	04/26/22 15:45	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-57 (Drinking Water)

LE-DW-0107 (Lenox)

Collected
04/19/2022 09:42

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 15:52	04/26/22 15:52	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-58 (Drinking Water)

LE-DW-0108 (Lenox)

Collected
04/19/2022 09:44

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 15:54	04/26/22 15:54	0.00273			0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-59 (Drinking Water)

LE-DW-0201 (Lenox)

Collected
04/19/2022 09:54

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 15:56	04/26/22 15:56	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-60 (Drinking Water)

LE-DW-0202 (Lenox)

Collected
04/19/2022 09:49

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 15:59	04/26/22 15:59	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-61 (Drinking Water)

LE-DW-0301 (Lenox)

Collected
04/19/2022 09:48

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 16:57	04/26/22 16:57	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-62 (Drinking Water)

LE-DW-0302 (Lenox)

Collected
04/19/2022 09:55

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 16:59	04/26/22 16:59	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-63 (Drinking Water)

LE-DW-0303 (Lenox)

Collected
04/19/2022 09:56

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 17:02	04/26/22 17:02	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-64 (Drinking Water)

LE-203 (Lenox)

Collected
04/19/2022 09:50

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 17:04	04/26/22 17:04	0.00211			0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-65 (Drinking Water)

LA-DW-0201 (Lakeside)

Collected
04/19/2022 10:16

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 17:06	04/26/22 17:06	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-66 (Drinking Water)

LA-DW-0101 (Lakeside)

Collected
04/19/2022 10:04

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 17:09	04/26/22 17:09	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-67 (Drinking Water)

LA-DW-0102 (Lakeside)

Collected
04/19/2022 10:09

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 17:11	04/26/22 17:11	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-68 (Drinking Water)

LA-DW-0103 (Lakeside)

Collected
04/19/2022 10:11

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 17:14	04/26/22 17:14	0.00294			0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-69 (Drinking Water)

LA-DW-0104 (Lakeside)

Collected
04/19/2022 10:12

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 17:16	04/26/22 17:16	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-70 (Drinking Water)

LA-DW-0105 (Lakeside)

Collected
04/19/2022 10:05

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 17:18	04/26/22 17:18	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-71 (Drinking Water)

LA-DW-0106 (Lakeside)

Collected
04/19/2022 10:07

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 17:25	04/26/22 17:25	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-72 (Drinking Water)

LA-DW-0107 (Lakeside)

Collected
04/19/2022 10:19

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 17:28	04/26/22 17:28	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-73 (Drinking Water)

HP-DW-01 (Hershfield)

Collected
04/19/2022 11:08

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 18:51	04/26/22 18:51	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-74 (Drinking Water)

HP-DW-02 (Hershfield)

Collected
04/19/2022 11:12

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 18:56	04/26/22 18:56	0.00285			0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-75 (Drinking Water)

HP-ICE-01 (Hershfield)

Collected
04/19/2022 11:10

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 18:58	04/26/22 18:58	ND	U		0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)



AQUA PRO-TECH LABORATORIES
Certified Environmental Testing

Analytical Results Summary

2040963-76 (Drinking Water)

HS-DW-RM-117 (High School)

Collected
04/19/2022 09:04

Received
04/20/2022 15:30

Contact
Billy Doty

Lab Section/ Analysis	Method	Prepared	Analyzed	Result	Qual	MDL	RL	Units
Total Metals								
Lead	EPA 200.8	04/26/22 19:01	04/26/22 19:01	0.00249			0.00200	mg/L

FootNotes

RL - Reporting limit
MDL - Minimum detection limit
ND, U - Indicates compound analyzed for but not detected
J - Indicates estimated value

B - Indicates compound found in associated blank
E - Concentration exceeds highest calibration standard
D - Indicates result is based on a dilution
P - Greater than 25% diff. between 2 GC columns
H - Indicates a Hold Time violation
D1 - Sample was Decanted (Dissolved)